

CONTRACTOR REQUEST FOR CLARIFICATION
Project: Fresno County Sheriff Area 2 Substation
Contract No.: 19-S-04

Requests for clarification of the drawings and specifications regarding this project shall be submitted on this form. Any change or clarification shall be in the form of a written addendum issued to Bid Document holders of record. Contractors requesting clarification shall complete the following:

Email to: DesignServices@fresnocountyca.gov

FIRM NAME: _____

SENDER / CONTACT NAME: _____

MAILING ADDRESS: _____

Zip Code

BUSINESS PHONE: _____ FAX NUMBER: _____

Drawing No.:	Spec Section:
--------------	---------------

Question Type or print one question below

Response

SEOR RESPONSE: A STEP IS NOT REQUIRED AT THE ENTRY DOOR 'F1' FOOTING DUE TO THE SHORT LENGTH OF THE FOOTING BETWEEN THE DEEPER FOOTINGS. THIS FOOTING HAS BEEN REVISED TO AN 'F2' TYPE. A STEPPED FOOTING IS NOT REQUIRED AT THE TRANSITION BETWEEN THE 'P3' AND 'F2' FOOTINGS ON GRIDLINES 'B' AND '7' AS THE 'P3' FOOTING WAS EXTENDED THRU THE 'P1' FOOTING. THE TYPICAL STEPPED FOOTING DETAIL WAS REVISED TO ALLOW A 2 FT. STEP.
FYI: THE STEPPED FOOTING DETAIL IS INTENDED FOR CONTRACTOR TO APPLY AS REQUIRED FOR FOOTING CONDITIONS WHERE THEY OCCUR.

The following section is for County use only.

Response By: <u>R.S. PARRISH</u>	Date: <u>6-16-2020</u>	
Included in Addendum No. _____	Date: _____	
Date Received: _____	Time Received: _____ am / pm	RFC Number: _____

This form may be removed from the project specifications and/or reproduced as needed.