

**ADDENDUM 02**

Contract # 20-S-01

Dated: 05-20-2021

The foregoing documents are amended in the respects as herein set forth. This addendum and the amendments herein shall become part of said documents and of any contract entered into pursuant to said documents.

**PLEASE ACKNOWLEDGE THIS ADDENDUM ON YOUR PROPOSAL. IF YOU HAVE GIVEN THE CONTRACT DOCUMENTS TO SOMEONE ELSE, PLEASE FORWARD THIS ADDENDUM.**



05.25.2021

Date Signed

Architect of Record: \_\_\_\_\_  
Tiana L. Perez, #C38000  
License Renewal 01/31/23

**Fresno County Department of Public Works and Planning  
Development Services & Capital Projects Division**  
2220 Tulare Street, 8<sup>th</sup> Floor  
Fresno, CA 93721-2104

**A. BID FORMS AND CONTRACT CONDITIONS:**

No changes

**B. SPECIFICATIONS:**

- a. Section 000004 Drawing Sheet Index
  - i. Page 4, Phase 3 – Warehouse Building, Mechanical Sheets: Delete “M2.1 Mechanical Schedules and Details”
  - ii. Page 5, Phase 3 – Warehouse Building: Adjust total sheet count from “27” to “26”

**C. DRAWINGS:**

**a. Phase 1 – Site Improvement and Shade Structure**

**i. A1.1 – Overall Site Plan**

- 1. Fire Department Connection symbol added to legend and located on site plan
- 2. Location of NFPA 704 placard noted at site entrance gate and drop off entrance gate
- 3. Note added under Fresno Fire Notes.

**ii. A1.2 – Enlarged Site Plan**

- 1. List of contents stored at the facility has been provided
- 2. Location of NFPA 704 placard is noted at drop off entrance gate
- 3. Wheelchair areas shown outside of Warehouse building and Office Building have been noted as “area of refuge”
- 4. Symbol for Fire Department Connections has been added to the Legend and locations of Fire Department Connections have been noted on plan
- 5. Note #5 has been removed from General Notes and Note #6 has been renumbered as #5.

**iii. A2.1 – Floor Plan & Exterior Elevations**

- 1. A1 has been renamed to “Floor Plan”
- 2. D10, G10, and K10 have been renamed to “Exterior Elevation”

**iv. A2.3 – Hazmat Container Reuse Center, Used Oil Storage**

- 1. G1 – Front elevation shows location of NFPA 704 placard.

**v. A2.4 – Seatrain Storage Containers, Hazmat Storage Containers, Anti-Freeze Tank Storage Unit**

- 1. F1 – Front elevation shows location of NFPA 704 placards. Note #3 has been added to General Notes.

**vi. E1.1 – Electrical Notes and Symbols**

- 1. Added note #27 under Electrical General Notes

**b. Phase 2 – Office/Storage Building**

**i. A1.1 – Reference Overall Site Plan**

- 1. Fire Department Connection symbol added to legend and located on site plan
- 2. Location of NFPA 704 placard noted at site entrance gate and drop off entrance gate
- 3. Note added under Fresno Fire Notes.

**ii. A1.2 Reference Enlarged Site Plan**

- 1. List of contents stored at the facility has been provided
- 2. Location of NFPA 704 placard is noted at drop off entrance gate
- 3. Wheelchair areas shown outside of Warehouse building and Office building have been noted as “area of refuge”

4. Symbol for Fire Department Connections has been added to the Legend and locations of Fire Department Connections have been noted on plan
5. Note #4 has been removed from General Notes and Note #5 has been renumbered as #4.
- iii. **A2.1 – Floor Plans and Elevations**
  1. D8 has been renamed to “Floor Plan”
- iv. **A2.2 – Reflective Ceiling Plan & Roof Plan**
  1. A1 has been renamed to “Reflective Ceiling Plan”
  2. A8 has been renamed to “Roof Plan”
- c. **Phase 3 – Warehouse Building**
  - i. **G0.0 – Cover Sheet**
    1. Note #11 added under General Notes
    2. Sheet M2.1 removed from Sheet Index and Mechanical sheet count revised to 2 sheets.
    3. Total sheet count revised to 26 sheets
  - ii. **A1.1 – Overall Site Plan**
    1. Fire Department Connection symbol added to legend and located on site plan
    2. Location of NFPA 704 placard noted at site entrance gate and drop off entrance gate
    3. Note added under Fresno Fire Notes.
  - iii. **A1.2 – Enlarged Site Plan**
    1. List of contents stored at the facility has been provided
    2. Location of NFPA 704 placard is noted at drop off entrance gate
    3. Wheelchair areas shown outside of Warehouse building and Office building have been noted as “area of refuge”
    4. Symbol for Fire Department Connections has been added to the Legend and locations of Fire Department Connections have been noted on plan
    5. Note #5 has been removed from General Notes and Note #6 has been renumbered as #4.
  - iv. **M2.1 – Mechanical Schedules and Details**
    1. Sheet deleted
  - v. **E1.1 – Electrical Notes and Symbols**
    1. Note # 27 added under Electrical General Notes

**D. GENERAL CLARIFICATIONS:**

1. Please note that Delta A clouds have been added for permitting agency clarifications only. These areas have not changed from the original bid sets. Delta 2 clouds reflect changes to the bid sets as explained in Addendum 02.
2. Please note that the Storm Water Pollution Prevention Plan has been posted as a supplemental document.