### **APPENDIX 1. NOTIFICATION TEMPLATE**

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.

Tradúzcalo o hable con alguien que lo entienda bien.

# Nitrate Monitoring Requirements Not Met for FCSA #10A/Mansionette Estates

Our water system failed to monitor as required for a drinking water monitoring standard during the 2022 Calendar Year and, therefore, was in violation of the monitoring regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the 2022 Calendar Year we did not test for nitrate on one of our wells and therefore cannot be sure of the quality of our drinking water during that time.

#### What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during the last year, how many samples we are required to take and how often, how many samples we many samples we took, when samples should have been taken, and the date on which followup samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Nitrate	Well 01 - Raw: 1 / Year Well 02 - Raw: 1 / Qtr	0 from Well 01 - Raw / 4 from Well 02 - Raw	2022 Calendar Year	February 10, 2023 and February 28, 2023

 If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

Description of corrective action:	
We anticipate resolving the problem within the estimated time frame:	
For more information, please contact:	
Name of Contact	
Phone Number	
Mailing Address	

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing

homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

## Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by FCSA #10A/Mansionette Estates.	
Date distributed:	